

File No.- FFE-B-F(2)-2/2016

Date: Shimla-171002, the 8-4-2016

Order

Sub :- Diversion of 53.5085 hectares of forest land for construction of 220KV/400KV/DC Transmission Line from 111MW Sawara Kuddu HEP TO LILO Point on 400 KV Jhakri-Abdullapur Transmission Line of M/s PGCIL in f/o HPPTCL at Village Ghunda, Tehsil Kotkhar, within the jurisdiction of Rohru and Theog Forest Divisions, in District Shimla, H.P.

भारत सरकार पर्यावरण एवं वन मन्त्रालय क्षेत्रीय कार्यालय देहरादून द्वारा वन (संरक्षण) अधिनियम 1980 की धारा-2 के अन्तर्गत जारी स्वीकृति पत्र संख्या 9-HPC 299/2013-CHA/2556 दिनांक 04.03.16 के परिणामस्वरूप राज्यपाल, हिमाचल प्रदेश उपरोक्त विषय में दर्शित 53.5085 हैक्टेयर वन भूमि को HPPTCL को उपयोग के लिए स्वीकृति निम्नलिखित शर्तें पूरी करने पर प्रदान करती है।

- 1 वन भूमि की विधिक परिस्थिति नहीं बदली जाएगी।
- 2 प्रतिपूर्ति पौधारोपण प्रस्ताव के अनुसार 107.00 हैक्टेयर [U.F.Kutara (15.7032ha), Jabal (10 ha), Khabal (10 ha), Telga (23.8740 ha), Jakha-C (20.00ha), Jakha-D (7.0052 ha)& U.F.Kishour (13.3158 ha), Chanodhar (7.1188 ha)] वन भूमि पर इस पत्र के जारी होने की तिथि से एक से दो वर्षों के अन्दर पूर्ण किया जाना चाहिए।
- 3 प्रयोक्ता अभिकरण द्वारा प्रस्तावित ट्रांसमिशन लाईन के नीचे, ROW के अन्दर जहाँ-जहाँ सम्भव हो, बौने पौधों (मुख्यतः औषधीय पौधों) के रोपण एवम् 7-10 वर्षों तक रख-रखाव वन विभाग द्वारा प्रयोक्ता अभिकरण से वृक्षारोपण योजना हेतु प्राप्त राशि के अनुसार इस पत्र के जारी होने की तिथि से एक से दो वर्षों के अन्दर पूर्ण किया जाना चाहिए।
- 4 Below each conductor or conductor bundle, 3m width clearance would be permitted for stringing purpose within the approved RoW.
- 5 Trees on such strips would have to be felled but after stringing work is completed, natural regeneration will be allowed to come up. Felling/pollarding/pruning of trees will be done with the permission of the local forest officer, where-ever necessary, to maintain the electrical clearance. One outer strip shall be left clear to permit maintenance of the transmission line.
- 6 During construction of transmission line, pollarding /pruning of trees located outside the above width of the strips, whose branches/parts infringe with conductor stringing, shall be permitted to the extent necessary, as may be decided by local forest officer.
- 7 Pruning of trees for taking construction/stringing equipments through existing approach/access routes in forest areas shall also be permitted to the extent necessary, as may be decided by local forest officer. Construction of new approach/access route will however, require prior approval under the Act.

Contd./2

- 8 In the remaining width of right of way trees will be felled or lopped within the RoW to the extent required, for preventing electrical hazards by maintaining minimum clearance between conductor and trees as follows: 4.6 m for 220 KV and 5.5 m for 400 KV
- 9 In the case of transmission lines to be constructed in hilly areas, where adequate clearance is already available, trees will not be cut except those minimum required to be cut for stringing of conductors.
- 10 एन.पी.वी. की दरों में अगर कोई बढ़ोतरी होती है तो प्रयोक्ता अभिकरण बड़ी हुई दरों पर एन.पी.वी. देने के लिए बाध्य होगा।
- 11 प्रयोक्ता अभिकरण द्वारा प्रस्तावित वन क्षेत्र के आस-पास मजदूरों / स्टॉफ के लिये किसी भी प्रकार का कैम्प नहीं लगाया जायेगा।
- 12 प्रयोक्ता अभिकरण के द्वारा निर्माण कार्य के दौरान स्थल पर कार्यरत मजदूरों एवं स्टॉफ के लिए रसोई गैस / कैरोसिन तेल की आपूर्ति की जायेगी, जिससे निकटवर्ती वनों को क्षति न पहुँचे।
- 13 परियोजना के निर्माण व रख-रखाव के दौरान आस-पास के क्षेत्र की वनस्पतियों एवं जीव-जन्तुओं को किसी प्रकार की क्षति नहीं पहुँचायी जायेगी।
- 14 वन भूमि का प्रयोग प्रस्ताव में दर्शाये गये उद्देश्य के अलावा अन्य किसी उद्देश्य के लिए नहीं किया जायेगा।
- 15 कम से कम वृक्षों का कटान / पातन किया जाएगा, जिनकी संख्या प्रस्ताव के अनुसार 486 से अधिक न हो।
- 16 प्रयोक्ता अभिकरण वन विभाग की देख-रेख में प्रत्यावर्तित भूमि का RCC Pillar लगाकर सीमांकन करेगा जिन पर Pillar no., Forward तथा Back bearing तथा distance between pillars भी अंकित किया जाएगा।
- 17 परियोजना निर्माण से उत्सर्जित मलवे का निस्तारण प्रयोक्ता अभिकरण द्वारा प्रस्तुत मलवा निस्तारण के अनुसार प्रभागीय वनाधिकारी की देख-रेख में किया जाएगा एवं निर्दिष्ट स्थानों के अलावा अन्यत्र मलवा नहीं फेंका जाएगा।
- 18 यदि कोई अन्य सम्बन्धित अधिनियम / अनुच्छेद / नियम / न्यायालय आदेश / अनुदेश आदि इस प्रस्ताव पर लागू होते हैं तो उनके अधीन जरूरी अनुमति लेना प्रयोक्ता एजेंसी की जिम्मेवारी होगी।
- 19 ऐसी अन्य कोई भी शर्त जो भारत सरकार भविष्य में पर्यावरण, वन एवं वन्य जीवों के संरक्षण हेतु आवश्यक समझें।
- 20 उपरोक्त शर्तों में से किसी भी शर्त का कार्यान्वयन सन्तोषप्रद नहीं पाए जाने पर, मन्त्रालय इस स्वीकृति को स्थगित / रद्द कर सकता है। वन विभाग हि0 प्र0 के माध्यम से इन शर्तों की अनुपालना सुनिश्चित की जायेगी।
- 21 A lease- deed of the forest land shall be executed by the user agency with Collector-cum- Deputy Commissioner, District Shimla, H.P.

आदेश अनुसार

प्रधान सचिव (वन)

हिमाचल प्रदेश सरकार शिमला -2

Dated, Shimla-171001 the, ... 8-4-2016

Contd./3

Endst. FFE-B-F(2)-2/2016 (FCA)

Copy is forwarded to :-

1. Additional Director General of Forests, MoEF, Paryavaran Bhawan, Aliganj, Jorbagh Road, New Delhi - 110003.
2. Additional Principal Chief Conservator of Forests. Regional Office, Dehradun, Pearson Road, New Forest, Dehradun.
3. The Pr.CCF (HoFF) with the request to ensure compliance of all conditions contained in the above order.
4. The Deputy Commissioner, Shimla, Distt. Shimla Himachal Pradesh.
5. Nodal Officer-cum-Addl.PCCF(FCA)HPFDHQ Shimla.
6. Conservator of Forests, Shimla / Rampur.
7. DFO, Forest Division Rohru, Distt. Shimla, H.P.
8. DFO, Forest Division Theog, Distt. Shimla, HP
9. HP Power Transmission Corporation Ltd. Khalani.
10. Guard File.

(Sat Pal Dhiman)

Deputy Secretary (Forests) to the
Government of Himachal Pradesh.

S/FCA
A.PCCF(FCA)
18/4

SA

Shu
22/4

प्र.सं.सं.सं. सि.
पा.सं. 922
दि. 2/9/16

12 2 APR 2016

Endst. No. Ft. 48-2589/2012(FCA)

Dated Shimla-1, the

Copy is forwarded to CF (IT) for information and necessary action. He is requested to upload the formal order as issued by Principal Secretary (Forests) to GoHP on the Web Site of Forest Department.

Nodal Officer-cum-Addl. Pr. CCF (FCA)
O/o Pr. CCF, H.P. Shimla-1